

Certificate of Product Approval

Certificate Number: 949c

Issue: 02

DUBAI CABLE COMPANY (PRIVATE) LIMITED

Ducab-M2
Plot No. – J6 14-15-16
Sector – M41
Industrial City of Abu Dhabi-1
Mussafah
Abu Dhabi
United Arab Emirates

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
Ducab Flam BICC 3 Multicore
See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 6387:2013 (Category CWZ)
EN 50267-2-1:1999
EN 61034-2:2005
IEC 60331-21:1999

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

David Hoare
Certification Manager

19 February 2015
Date of Issue

11 February 2015
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 949c DUBAI CABLE COMPANY (PRIVATE) LIMITED

Issue: 02

Product name					LPCB Ref. No.
Ducab Flam BICC 3 Multicore					949c/01
Nominal csa of conductor (mm ²)	Core Construction	BS 6387	EN 50267-2-1	EN 61034-2	IEC 60331-21
1.0	2,3 & 4 ⁽¹⁾	CWZ	<0.5% HCl	>60%	Complies ⁽²⁾
1.5	2,3 & 4 ⁽¹⁾	CWZ	<0.5% HCl	>60%	Complies ⁽²⁾
2.5	2,3 & 4 ⁽¹⁾	CWZ	<0.5% HCl	>60%	Complies ⁽²⁾
4.0	2,3 & 4 ⁽¹⁾	CWZ	<0.5% HCl	>60%	Complies ⁽²⁾
6.0	2,3 & 4 ⁽¹⁾	CWZ	<0.5% HCl	>60%	Complies ⁽²⁾
10	2,3 & 4 ⁽¹⁾	CWZ	<0.5% HCl	>60%	Complies ⁽²⁾
16	2,3 & 4 ⁽¹⁾	CWZ	<0.5% HCl	>60%	Complies ⁽²⁾

Uo/U 600/1000V

Notes:

1. Stranded conductor only.
2. The Ducab Flam BICC 3 Multicore cables met the requirements of IEC 60331-21: 1999 when tested at a temperature of 950°C for a duration of 90mins + 15mins cool down, at a voltage of 600V.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

David Hoare
Certification Manager

19 February 2015
Date of Issue

11 February 2015
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com


